



January 31, 2012

DEMA ENGINEERING CO.
ENGINEERING
JAMES SCHLUETER
10020 BIG BEND BLVD.
ST. LOUIS MO 63122

Re: Description: PROPORTIONER
Manufacturer: DEMA ENGINEERING CO.
Product Name: BLEND CENTERS
Model Number(s): 633AG-1, 633AG-4, 635AG-1, 635AG-4, 637AG-1, 637AG-4, 639AG-1, 639AG-4, 661AG-4, 661AGB, 661AGDB, 662-AG-1, 662-AG-4, 662-2AGDB-11, 662-2AGDB-14, 662-2AGDB-44, 662-2AG-11, 662-2AG-14, 662-2AG-44, 662-3AG-1, 662-3AG-114, 662-3AG-144, 662-3AG-4, 662-4AG-1111-2, 662-4AG-1114-2, 662-4AG-1144-2, 662-4AG-1111-4, 662-4AG-1114-4, 662-4AG-1144-4, 662-635AG-1, 662-635AG-4, 662-637AG-1, 662-637AG-4, 662-639AG, 681AG-1, 681AG-2, 681AG-3, 681AG-4, AND 681AG-5
Product File No: 20120051

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 82.41 (3) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed with the pressure indicating tee permanently attached to the inlet of the supply hose serving this product.

This approval supersedes the approval issued on August 26, 2008 under product file number 20050797.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050797.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov